



COASTSIDE FIRE PROTECTION DISTRICT

OFFICE OF THE FIRE MARSHAL

Address: 1191 Main Street, Half Moon Bay, CA, 94019 | Phone: (650) 345-1612

Email: cfpdfiremarshal@fire.ca.gov | Website: www.coastsidefire.org

STANDARD DETAIL AND SPECIFICATION MANUAL

| | |
|---------------------------------------|--|
| Section: Developer Information | Title: Cannabis Cultivation Policy |
| Effective: January 1, 2018 | Revised: May 7, 2019 |
| Number: DI-014 | Authorized By: Gary Silva, Fire Marshal |

SCOPE:

This document is intended to provide the information required to meet the requirements for the cultivation of cannabis in Coastside Fire Protection District.

STANDARDS:

1. Do you have the proper state and local permits for growing?
2. If needed do you have building permits?
3. Plans for permits need to include quantities of hazardous materials (including fuels, compressed gasses, fertilizers and where they are located.)
4. Is CO2 enhancement being used? If yes the system must comply with CFC. Chapter 53 and NFPA chapter 55. An emergency alarm system will be required.
NFPA 704 placards for simple asphyxiates shall also be provided at the exterior main entrance and at each entrance to storage rooms/areas.
A sign shall have a minimum 1-inch block lettering with a minimum 4-inch stroke. The sign shall be on a contrasting surface of black on yellow and shall be of durable construction.
Signage on entrance doors to grow cultivation and storage rooms: Signage shall be provided at entrance doors to each grow cultivation room/area and at each entrance to storage rooms/ areas: Danger Potential Deficient Atmosphere
5. Plans for site security, a Knox Box will be required.
6. Fire sprinklers maybe required depending if or what modifications are done to the structure.
7. **These guidelines do not cover the extraction processes**