

ADDENDUM

ADDENDUM: 02
DATE: JUNE 13, 2018
PROJECT: COASTSIDE FIRE STATION 41
PREPARED BY: Jeff Katz (jeff@jeffkatzarchitecture.com)
Jeff Katz Architecture
280 Bettencourt Street
Sonoma, California 95476
(619) 698-9177

This addendum is issued before the award of contract to inform the bidders of revisions to the bidding documents.

All requirements contained in the bidding documents shall apply to this addendum, and the general character of the work called for in this addendum shall be the same as originally set forth in the applicable portions of the bidding documents for similar work, unless otherwise specified under this addendum, and all incidental work necessitated by this addendum as required to complete the work shall be included in the bids, even though not particularly mentioned in this addendum.

This addendum is hereby made a part of the bidding documents and shall be signed and included in the bid package.

The bid date and time remain unchanged.

DRAWINGS ISSUED WITH ADDENDUM:

- No drawings are issued with this addendum.
- The following drawings are issued with addendum and form a part hereof.

DRAWINGS

1. Sheet A1.3 SITE DETAILS

- a. Details and notes reference a fabricated fence and gate system, with all items hot dip galvanized after fabrication. At contractor option, a pre-galvanized, powder coated panels bolted to posts with brackets is acceptable. Products shall maintain design profile noted. Fence and gate panels shall be by Ameristar Fence, or equal.
- b. Fence panels shall be installed in sleeves in retaining wall, with sleeves embedded a minimum of 12".
- c. Gate hardware (Hardware Set 18) shall be modified to include a rim exit device (Series 2100).

2. Sheet A3.1,
A3.2,A3.3, A7.9 EXTERIOR ELEVATIONS & DETAILS

- a. Notes 277, 281, 282 & 283: Revise ANY references to "Glass Fiber Reinforced Concrete Trim" to read "Fiberglass Reinforced Plastic Fabrications". Reference Specification Section 06612 for additional information.

END OF ADDENDUM

All bidders shall acknowledge receipt and acceptance of this Addendum No. 01 by signing in the space provided and submitting the signed Addendum No. 01 with the bid. Failure to include this addendum may be cause for the rejection of the bid.

RECEIPT ACKNOWLEDGED BY:

DATE: _____